

QUICK-REFERENCE INSTALLATION GUIDE

NETCOM[®] MODEL ADH AUTOMATIC AIR DEHYDRATOR WITH AC POWER SUPPLY





CONNECTIONS

1. Connect feed hose to 1/8" NPT outlet using 1/4" or 3/8" barbed fitting supplied.
2. Connect required data and alarm relay ports. RS-422 and RS-232 ports may require configuration changes via the web interface. See Instruction Manual for more information.
3. Connect AC power. System can be connected to 100 VAC - 240 VAC power without requiring any configuration change.

QTY.	PART NO.	DESCRIPTION
1	25526	ADH NETCOM, AC
1	25547	ADH NETCOM, AC Installation Sheet (this document)
1	18198	1/8" NPT to 1/4" Barbed Brass Fitting
1	23428	1/8" NPT to 3/8" Barbed Brass Fitting
1	14513	1/8" NPT to 1/4" Barbed Elbow Brass Fitting
4	23245	Mounting Bracket
8	24567	Self-Locking Rack-mounting screw (#8-32)
8	10641	#8 Split Washer


QUICK-REFERENCE INSTALLATION GUIDE



RACK MOUNTING

The dehydrator is equipped with positions for either flush-mounting (for dual-post racks and enclosures) or center-mounting (for single-post racks).


If using mounting rails (not supplied), do not install mounting brackets.



WALL MOUNTING CONFIGURATION

To configure the dehydrator for wall mount installation, remove the front panel and the portion of the vented cover with the ETI logo.

Reinstall the front panel so that it will be in the new front position once the dehydrator is positioned for wall mounting. Reinstall the small vented panel so that it will be in the new bottom position.



WALL MOUNTING

Ensure the mounting surface and hardware are suitable to support a static load of approximately four times the weight of the unit, or 64 pounds (29 kg). Use four appropriate 5/16" mounting fasteners to attach the unit and ensure stable mounting. The dehydrator is equipped with four brackets for wall mounting.

QUICK-REFERENCE INSTALLATION GUIDE

NOTE:

Your Information Technology Department is the best source of information if you encounter problems or difficulties in connecting to or communicating with the dehydrator. The ADH NETCOM Ethernet communications run at 10Base-T and half duplex. It is recommended that the network interface to the ADH NETCOM be manually set to these parameters and NOT to an auto-configure mode.


After changing the IP address of your dehydrator to a network other than the default 192.168.52.0 you will not be able to access the dehydrator from the configuring computer unless that computer is reconfigured for the newly assigned network address.

IP SETTINGS

1. Temporarily assign computer an IP address in the 192.168.52.0 network range, typically 192.168.52.1, with the subnet 255.255.255.0
2. Connect the dehydrator to your computer either directly or through a network. For direct connections a cross-over cable or switch may be required for connecting to an older computer; an Ethernet patch cable will work in most other cases.
3. Open a web browser and connect to web interface at HTTP: //192.168.52.9

CONFIGURING IP ADDRESS

1. Go to Configuration page
2. If using a fixed IP address, select "Use the following IP address:" Then set the IP address, mask and gateway.
3. If using DHCP, select "**Obtain IP Address Automatically.**"
4. Click Submit. You should see a message that the dehydrator is rebooting.



IP Pressure Parameters Module

CONFIGURING PRESSURE

1. Using a web browser, connect to the dehydrator. Go to the Configuration page
2. Using the Units pull-down select English (PSI) or SI (mbar).
3. To change the operational pressure setting enter the following:


Low Alarm - The pressure at which Low Pressure will cause an alarm condition.

Low Limit - The low set point at which the unit will start pumping.

High Limit - The high set point at which the unit will stop pumping.

High Alarm - The pressure at which High Pressure will cause an alarm condition.

4. Click submit.



Configuration Module

